

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**R.NO. 3457 /A3/2025****DATE: 02- .05.2025.**

It is certified that an inspection team headed by PUBLIC HEALTH
(NAME OF OFFICERS WITH DESIGNATION) from C. Kaliappan, Block Health
Supervisor (Name of department / office) inspected the Government Primary Health
Centre, Kanjampatti , Pollachi south, Coimbatore (name & Address of the School) on
02.05.2025 (date of Inspection) and found that the **NACHIAR THE WORLD SCHOOL**
(Name of School) has safe drinking water facilities for the students and members of
staff of the institution and is maintaining he hygienic sanitation condition in the
school building & the campus as per norms prescribed by the central / state/ U.T.Govt.

The above is valid a period of **ONE YEAR**

C. Kaliappan
Block Health Supervisor
Govt. Primary Health Centre
Kanjampatti - 642 003

Name : C. Kaliappan
Designation : Block Health Supervisor
Name & address of the Office / Department

Counter Signed

[Signature]
District Health Officer,
Coimbatore District.

To
Nachiar The World School
56 Meenkarai Road,
Zaminuthukuli,
Pollachi 642004.



APPENDIX-XII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

LDis .NO.3457/A3/2025

DATE:02.05.2025

It is certified that an inspection team headed by PUBLIC HEALTH (Name of Officers with designation) from C.Kaliappan, Block Health Supervisor (Name of Department / office) inspected the Government Primary Health Center, Kanjampatti, Pollachi South, Coimbatore (Name & Address of the School) on 02.05.2025 (date of inspection) and found that the **NACHIAR THE WORLD SCHOOL** (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T.Govt.

The above is valid a period of ONE YEAR

_____Sd_____

Singnature with seal
Block Health Supervisor
Govt. Praimary Helath Center
Kanjampatti -642003

Name:C.Kaliappan
Dessignation:Block Health Supervisor
Name&address of the Office /Department

Counter Signed


_____Sd_____

14/05/2024

Deputy Director of Health services,
Coimbatore District.

TO

Nachiar The World School
56 Meenkarai Road,
Zaminuthukuli,
Pollachi 642 004.



27 MAY 2025

R. RADHAKRISHNAN, B.A., L.L.B.,
ADVOCATE & NOTARY PUBLIC
Modern Complex, Marappan Street,
POLLACHI - 642 001.

Translation of Round Seal


Office of District Health
Coimbatore -641018
14 MAY 2025

Translated the Tamil version of the Office seal in the **PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE** , in L.Dis No. 3457/A3/2025 Dated 02.05.2025 issued by Block Health Supervisor, Kanjampatti in to English Language.

RR-7

27 MAY 2025

R. RADHAKRISHNAN, B.A.,LL.B.,
ADVOCATE & NOTARY PUBLIC
Modern Complex, Marappan Street,
POLLACHI - 642 001.





TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 30, Siruvani Nagar Campus, Bharathi Park Road,

Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 51747-1	Report Issue Date :	28.04.2025	Page No : 1 of 1
Invoice Details:	9272/Dt.23.04.2025/Amt.1652/-	ULR No : - NA -		

Client Name & Address	: M/s. Nachiar The World School, No.56, Meenkarai Road, Zamin Uthukuli, Pollachi, Coimbatore. ✓			
Contact No / Email.ID				
Sample / Lab No	2025/51747 ✓			
Sample Name	: Water - Drinking Water			
Sample Description	: Clear, Colorless, Liquid ✓			
Sample Source	Tap Water ✓			
Sample Submitted by	: Customer			
Location & Date	: Within the School Premises & 23.04.2025			
Sample Container	: Plastic – Good Condition			
Quantity of Sample Received	: 2 Litre	Sample Condition on Receipt	:	Good
Sample Received on	: 23.04.2025	Environmental Condition Temp °C	:	23 – 27 °C
Test Commenced on	: 23.04.2025	Test Completed on	:	24.04.2025 ✓

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	--	IS 3025: Part 11: 2022	7.5	6.5-8.5	No Relaxation
2	Total Hardness as CaCO ₃	mg/L	IS 3025: Part 21: 2009 (RA:2023)	72	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	52	200	600
4	Chloride as Cl	mg/L	IS 3025: Part 32: 1988 (RA:2019)	51	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025: (Part 24/Sec 1): 2022 – Turbidity Method	15	200	400
6	Nitrate as NO ₃	mg/L	IS 3025: (Part 34/Sec-1): 2023 – Screening Method	< 2.0	45	No Relaxation
7	Fluoride as F	mg/L	IS 3025: (Part 60/Sec-1): 2023 - SPADNS Method;	< 0.2	1.0	1.5

Remark: The tested sample confirmed to IS: 10500:2012 (RA: 2023) Drinking Water Permissible Limit specification with respect to above tested parameters.

---End of Report-----

Reviewed and Authorised by

P. Gopalan, Assistant Water Analyst
TWAD Board, D.W.T.Lab,
Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 30, Siruvani Nagar Campus, Bharathi Park Road,

Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863


TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 51747-2	Report Issue Date :	28.04.2025	Page No : 1 of 1
Invoice Details:	9272/Dt.23.04.2025/Amt.1652/-			

Client Name & Address	: M/s. Nachiar The World School, No.56, Meenkarai Road, Zamin Uthukuli,		
Contact No / Email.ID	Pollachi, Coimbatore.		
Sample / Lab No	2025/51747		
Sample Name	: Water - Drinking Water		
Sample Description	: Clear, Colorless, Liquid		
Sample Source	Tap Water		
Sample Submitted by	: Customer		
Location & Date	: Within the School Premises & 23.04.2025		
Sample Container	: Plastic – Good Condition		
Quantity of sample Received	: 2 Litre	Sample Condition on Receipt	: Good
Sample Received On	: 23.04.2025	Environmental Condition Temp °C	: 23 – 27 °C
Test Commenced on	: 23.04.2025	Test Completed on	: 24.04.2025

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Turbidity	NTU	IS 3025: Part 10: 2023	< 0.5	1	5
2	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	205	500	2000
3	EC @ 25°C	µS/cm	IS 3025: Part 14: 2013	301	--	--
4	P- Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	Nil	--	--
5	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	14	75	200
6	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	9	30	100
7	Sodium as Na	mg/L	IS 3025: Part 45: 2024	30	--	--
8	Potassium as K	mg/L	IS 3025: Part 45: 2024	3	--	--


Reviewed and Authorised by
P. Gopalan, Assistant Water Analyst
TWAD Board, D.W.T.Lab,
Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY****No. 30, Siruvani Nagar Campus, Bharathi Park Road,****Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863****TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 51747-2 ✓	Report Issue Date :	28.04.2025	Page No : 2 of 1
Invoice Details:	9272/Dt.23.04.2025/Amt.1652/-			

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
9	Iron as Fe mg/L	mg/L	IS 3025 (Part 53) : 2024	< 0.1	0.3	No Relaxation
10	Manganese as Mn	mg/L	IS 3025 (Part 59) : 2023	< 0.1	0.1	0.3
11	Ammonia as NH ₃	mg/L	IS 3025 (Part 34) : 2023	< 0.1	0.5	No relaxation
12	Nitrite as NO ₂	mg/L	IS 3025 (Part 34/Sec-1) : 2023	< 0.01	--	--
13	Phosphate as PO ₄	mg/L	IS 3025 (Part 31/Sec-1) : 2022	< 0.1		
14	Oxygen Observed in 4 hrs.as O ₂ (Tidy's Test)	mg/L	IS 3025 (Part 63) : 2007	0.24	--	--
15	Residual Chlorine	mg/L	IS 3025 (Part 26) : 2007	0.2	0.2	1.0

Bacteriological Test

1	Fecal coliform	CFU / 100 ml	APHA 23 rd Edition 2017 – 2130 B	Absent	Absent/ 100 mL
---	----------------	--------------	---	--------	----------------

Remark: The tested sample confirmed to IS: 10500:2012 (RA: 2023) Drinking water Permissible Limit specification with respect to above tested parameters.

---End of Report----

Reviewed and Authorised by
P. Gopalan Assistant Water Analyst
TWAD Board Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.