

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.3711/A3/2026

Dated:30.04.2026

It is certified that an inspection team headed by Shri. C. Kaliappan, Block Health Supervisor (Name of Officers with designation) from Government Primary Health Centre, Kanjampatti, Pollachi South, Coimbatore (PHED) inspected Nachiar-The World School, 56 Meenkarai Road, Zamin Uthukuli, Pollachi-642004 (Name & Address of the school) on 18.04,2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no TR/2026/53028-1 dated 17.04.2026 of Tamilnadu Water Supply and Drainage Board District Water Testing Laboratory (PHEDLab) certified that Nachiar - The World School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 29.04.2027

C. Kaliappan
Block Health Supervisor
Govt. Primary Health Centre
Kanjampatti - 642 003

30/04/26

Signature with Seal:

Name: C. Kaliappan

Designation: Block Health Supervisor

Name & Address of the Office / Department:
Government Primary Health Centre,
Kanjampatti, Pollachi South, Coimbatore.

To
Nachiar-The World School,
56, Meenkarai Road,
Zamin Uthukuli,
Pollachi -642004
(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.3711/A3/2026

Dated:30.04.2026

It is certified that an inspection team headed by Shri. **C. Kaliappan**, Block Health Supervisor (Name of Officers with designation) from **Government Primary Health Centre, Kanjampatti, Pollachi South, Coimbatore (PHED)** inspected **Nachiar-The World School, 56 Meenkarai Road, Zamin Uthukuli, Pollachi-642004** (Name & Address of the school) on **18.04.2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no **TR/2026/53028-1** dated **17.04.2026** of **Tamil nadu Water Supply and Drainage Board District Water Testing Laboratory (PHEDLab)** certified that **Nachiar - The World School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **29.04.2027**

Sd _____

30.04.2026

Signature with Seal:

Block Health Supervisor

Govt.Primary Health Supervisor

Kanjampatti-642003



Name: **C. Kaliappan**

Designation: **Block Health Supervisor**

Name & Address of the Office / Department:

**Government Primary Health Centre, Kanjampatti,
Pollachi South, Coimbatore**

RR

16 MAY 2026

**R. RADHAKRISHNAN, B.A.,LL.B.,
ADVOCATE & NOTARY PUBLIC
Modern Complex, Marappan Street,
POLLACHI - 642 001.**

To
Nachiar-The World School,
56, Meenkarai Road,
Zamin Uthukuli,
Pollachi -642004
(Name & Address of the Institution)

Translation of Round Seal

Government Primary Health Centre,
Kanjampatti -642003
Date:30.04.2026

Translated the Tamil version of the office seal in the **PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**, in R.NO.3711/A3/2026 Dated 30.04.2026 issued by Block Health Supervisor, Kanjampatti into English Language



RR

1.6 MAY 2026

**R. RADHAKRISHNAN, B.A.,LL.B.,
ADVOCATE & NOTARY PUBLIC
Modern Complex, Marappan Street
POLLACHI - 642 001.**



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY

TWAD Board, Siruvani Nagar Campus., 30, Bharathi Park Road,
Coimbatore - 641043.

Phone: 0422 - 2437863

E-mail: twadlabcbce@gmail.com



TC-15968

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/ 53028-1	Report Issue Date :	17.04.2026	Page No : 1 of 1
Invoice Details:	9725/Dt.13.04.2026/Amt.1652/-	ULR No :	ULR No : TC - 107982610000024F	

Client Name & Address	: M/s. Nachiar The World School, No.56, Meenkarai Road, Zamin Uthukuli, Pollachi, Coimbatore.		
Contact No / Email.ID			
Sample / Lab No	2026/53028		
Sample Name	: Water - Drinking Water		
Sample Description	: Clear, Colorless, Liquid		
Sample Source	Tap Water		
Sample Submitted by	: Customer		
Location & Date	: Within the School Premises & 13.04.2026		
Sample Container	: Plastic – Good Condition		
Quantity of Sample Received	: 2 Litre	Sample Condition on Receipt	: Good
Sample Received on	: 13.04.2026	Environmental Condition Temp °C	: 23 – 27 °C
Test Commenced on	: 13.04.2026	Test Completed on	: 13.04.2026

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	--	IS 3025: Part 11: 2022	7.1	6.5-8.5	No Relaxation
2	Total Hardness as CaCO ₃	mg/L	IS 3025: Part 21: 2009 (RA:2023)	42	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	40	200	600
4	Chloride as Cl	mg/L	IS 3025: Part 32: 1988 (RA:2019)	25	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025: (Part 24/Sec 1): 2022 – Turbidity Method	6	200	400
6	Nitrate as NO ₃	mg/L	IS 3025: (Part 34/Sec-1): 2023 – Screening Method	0	45	No Relaxation
7	Fluoride as F	mg/L	IS 3025: (Part 60/Sec-1): 2023 - SPADNS Method;	< 0.2	1.0	1.5

Remark: The tested sample confirmed to IS: 10500:2012 (RA: 2023) Drinking Water Specification within the acceptable limit in respect to above tested parameters.

P. Gopalan
17/04/2026
Reviewed and Authorised by
P. Gopalan - Assistant Water Analyst
Assistant Water Analyst
TWAD Lab,
Coimbatore

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the Laboratory.
- The test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.

---End of Report----

Issue N / Date	01/01.09.2024	Amend .No / Date	00/-	Page No	1 of 1
----------------	---------------	------------------	------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 30, Siruvani Nagar Campus, Bharathi Park Road,

Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863

TEST REPORT


Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/ 53028-2	Report Issue Date :	17.04.2026	Page No : 1 of 1
Invoice Details:	9725/Dt.13.04.2026/Amt.1652/-			

Client Name & Address : M/s. Nachiar The World School, No.56, Meenkarai Road, Zamin Uthukuli, Pollachi, Coimbatore.
Contact No / Email.ID

Sample / Lab No	2026/53028		
Sample Name	Water - Drinking Water		
Sample Description	Clear, Colorless, Liquid		
Sample Source	Tap Water		
Sample Submitted by	Customer		
Location & Date	Within the School Premises & 13.04.2026		
Sample Container	Plastic – Good Condition		
Quantity of sample Received	2 Litre	Sample Condition on Receipt	Good
Sample Received On	13.04.2026	Environmental Condition Temp °C	23 – 27 °C
Test Commenced on	13.04.2026	Test Completed on	13.04.2026

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Turbidity	NTU	IS 3025: Part 10: 2023	< 0.5	1	5
2	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	118	500	2000
3	EC @ 25°C	µS/cm	IS 3025: Part 14: 2013	173	--	--
4	P- Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	Nil	--	--
5	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	8	75	200
6	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	5	30	100
7	Sodium as Na	mg/L	IS 3025: Part 45: 2024	17	--	--
8	Potassium as K	mg/L	IS 3025: Part 45: 2024	1	--	--


17/04/2026
Reviewed and Authorised by
P. Gopalan - Assistant Water Analyst
Assistant Water Analyst
TWAD Board Coimbatore Lab.
Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue N / Date	01/01.09.2024	Amend .No / Date	00/-	Page No	1 of 2
----------------	---------------	------------------	------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 30, Siruvani Nagar Campus, Bharathi Park Road,

Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2026/ 53028-2	Report Issue Date :	17.04.2026	Page No : 2 of 1
Invoice Details:	9725/Dt.13.04.2026/Amt.1652/-			


S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
9	Iron as Fe mg/L	mg/L	IS 3025 (Part 53) : 2024	< 0.1	0.3	No Relaxation
10	Manganese as Mn	mg/L	IS 3025 (Part 59) : 2023	< 0.1	0.1	0.3
11	Ammonia as NH ₃	mg/L	IS 3025 (Part 34) : 2023	< 0.1	0.5	No relaxation
12	Nitrite as NO ₂	mg/L	IS 3025 (Part 34/Sec-1) : 2023	< 0.01	--	--
13	Phosphate as PO ₄	mg/L	IS 3025 (Part 31/Sec-1) : 2022	< 0.1		
14	Oxygen Observed in 4 hrs.as O ₂ (Tidy's Test)	mg/L	IS 3025 (Part 63) : 2007	0.24	--	--
15	Residual Chlorine	mg/L	IS 3025 (Part 26) : 2007	0.2	0.2	1.0

Bacteriological Test

1	Fecal coliform	CFU / 100 ml	APHA 23 rd Edition 2017 – 2130 B	Absent	Absent/ 100 mL
---	----------------	--------------	---------------------------------------------	--------	----------------

Remark: The tested sample confirmed to IS: 10500:2012 (RA: 2023) Drinking Water Specification within the acceptable limit in respect to above tested parameters.

---End of Report----


15/4/2026

Reviewed and Authorised by
P. Gopalan - Assistant Water Analyst
Assistant Water Analyst
TWAD Lab, Siruvani Nagar,
Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the Laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

Issue N / Date	01/01.09.2024	Amend .No / Date	00/-	Page No	2 of 2
----------------	---------------	------------------	------	---------	--------